

REPORT OF CHEMICAL ANALYSIS  
REPORT NUMBER 2700745

RECEIVED

25 JUN 2007

Narrandera Shire Council

141 East Street

Narrandera

NSW

2700

Lab. Ref. No.	DOH No.	Township	Sampling Point	Sampling Date	Date Received
2702098	Bore 2A		Untreated Water	14/05/2007	18/05/2007
2702099	Bore 2A		Treated Water	14/05/2007	18/05/2007
2702100	Bore 4		Untreated Water	16/05/2007	18/05/2007
2702101	Bore 4		Treated Water	16/05/2007	18/05/2007

	2702098	2702099	2702100	2702101
Iron	0.84	0.15	1.73	0.04
Manganese	0.085	<0.005	0.093	<0.005
Total Hardness as CaCO <sub>3</sub>	75.7	76.5	223.3	222.3
Turbidity	3.3	0.4	21.9	0.1

105 JUL 2007

BY: .....

GM	Mayor	Mgr IWS			
EA	Cr Envelope	Mgr Works			
EDO	Info Paper	Mgr OSR			
DCS		Mgr Finance			
DECS		Mgr Rates			
DTS	HRAT/RO	Mgr HPBS			
File:	ED/63-	A = Action			
		I = Information			

Results in mg/L except for Turbidity(NTU), Colour (CU), Conductivity (µS/cm) and pH  
Please Note : The results of analysis contained in this report refer only to the sample(s) tested.  
Circled values exceed Australian Drinking Water Guidelines

Date : Friday, 15 June, 2007

Page No. : 1

Choon Wong

(Acting Laboratory Manager)